

Fire



rfo-sfps-surat@gujarat.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2023/00035495
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2023/00035495/R1

Date: 18/11/2025

Building Occupancy/Category: Educational (non-residential)

To,

SHAH NIKHILBHAI RAMESHCHANDRA
S No 143 144 At.Tandkva Vyara VYARA Tapi 394650
Fire Region: Surat RFO
Mobile No: 9925204866 Email ID: cnkotharicollege@gmail.com

We have received Application No.2025/00143655 dated 04/10/2025 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise C N kothari Medical College And Reserch Centre And Kalidas Hospital (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: 143 144
4. Village Name: Vyara
5. Name of Block(s): C N kothari Medical College And Reserch Centre And Kalidas Hospital


The building/premise was inspected on 18/11/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 18/11/2025
2. Six monthly inspection was done on 18/11/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 18/11/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:18/11/2025 3:40:00 PM



Digitally Verified
Digitally verified by: Hiranang Shirishbhai Patel
Fire Safety Officer - General (FSO-G)
2021/001285
Reviewed by : RFO Surat
Date: 18/11/2025
Time: 04:17 PM

MEDICAL SUPERINTENDENT
Kalidas Homoeopathic Hospital
Tadkva, Vyara.



FSCA/O/RFOSRT/2023/00035495/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.